

## SUB-PLAN FOR UPGRADING SUBSTANDARD FACILITIES

## SPRING GARDEN SCHOOL

## Rm B-1

## Permanent Approval Requirements

1. Space exceeds 4' below grade.  
While the classroom floor is less than 4 ft. below grade, an occupant of the room must ascend more than 4 ft. to reach the outside grade. He must ascend 7'-7" to the entrance platform, then go down to the outside grade.

Solution - request a waiver of this requirement.

2. Standard tempered outdoor air supply needed.

Solution - Install unit ventilator ducted to outside.

3. Window stools exceed 3'-6" above finished floor. They are actually 4'-3 1/2" from floor.

Solution - include in waiver request.

4. Combustible wall paneling not permitted.

Solution - remove wood paneling and replace with masonite paneling.

## Rm B-2

Same requirements and same solutions as for B-1.

## Comp. Ed. Rm

## Permanent Approval Requirements

1. Standard tempered outdoor air supply.  
Existing ceiling-mounted unit ventilator is ducted only to the inside of the window. When window is closed, outdoor air is prevented from entering.

Solution - replace upper sash with a solid panel with univent intake ducted through it.

2. Combustible wall paneling.

Solution - remove wood paneling and replace with masonite paneling.

3. Space exceeds 4 ft. below grade
4. Ceiling height less than 9'-6".

Solution (3 & 4) - since these items cannot be rectified, request a waiver.

FRANKLIN SCHOOL

Resource Room

Permanent Approval Requirements

1. Standard tempered outdoor air supply.

Solution - we removed the partition separating this space from the adjoining space, which has the unit ventilator in it. This separating partition was not in the original design.

2. Combustible wall paneling.

Solution - remove wood paneling and replace with masonite paneling.

YANTACAW SCHOOL

Rm 101 (Resource Rm)

Permanent Approval Requirements

1. Combustible wall paneling.

Solution - remove wood paneling and replace with masonite paneling.

2. Ceiling height less than 9'-6".

3. Sill height above 3'-6".

Solution (2 & 3) - request a waiver of these requirements.

Rm 102 (First Grade)

Permanent Approval Requirements

1. Ceiling height less than 9'-6".

Solution - request a waiver of this requirement.

Rm 103 (First Grade)

Permanent Approval Requirements

1. Combustible wall paneling.

Solution - remove wood paneling and replace with masonite paneling.

2. Ceiling height less than 9'-6".

YANTACAW SCHOOL (continued)

Rm 103 (First Grade - continued)

3. Sill height above 3'-6".

Solution (2 & 3) - request a waiver of these requirements.

Rm 104 (Second Grade)

Permanent Approval Requirements

1. Ceiling height less than 9'6".

Solution - request a waiver of this requirement.